



## **ANNEX 4 to the Tender Specifications**

### ***Current security installations and equipment at the EEA***

#### ***Access control and Burglar system (NOX) and theft surveillance***

A NOX burglar system is installed at KN6, connecting all alarm points in KN6 and KN8. Altogether there are currently approximately 350 alarm points in the Agency's premises. From the central in KN6 a signal is transferred to the current security contractors. A CCTV system covers live monitoring to a Control Centre. It includes currently six cameras and a hard disk recorder

There are currently 21 Roger PRT12 Card readers programmed for chip cards, and magnetic locks. Access card are printed at EEA, using equipment supplied by the current security contractor. The contracted security company is also responsible for maintenance and service of the outer main gate and the inner glass gate (ordering services after prior approval by the Agency)

#### ***Automatic fire alarm system (ABA)***

EEA has an automatic fire alarm central covering all floors at KN6, with a direct signal to the fire brigade and to our NOX system and to the security company. In KN8 there is a fire central for the whole house maintained by the landlord.

The fire central in KN8 also sends a signal to NOX system and to the security company.

The ABA includes:

- One central fire alarm unit including power supply and emergency power supply
- One signal transmission device for contact with the Copenhagen fire service
- One signal transmission device for contact with the Dansikring A/S control centre
- 93 alarm sirens
- 149 optical smoke detectors
- 252 ion smoke detectors
- 233 heat detectors
- 53 alarm buttons

The installations are subject to a yearly inspection carried out by Dansk Brand- og Sikringsteknisk Institut (the Danish Fire Safety Institute).

There are two separate fire fighting systems installed in KN6, with a direct signal to the fire central system, to fire brigade and the security company.

- In the basement: Fire Eater installed with 4 bottles containing energen'
- In the server room at the 3rd floor: Argonite with 9 bottles of argonite.

## **Fire equipment and first aid**

- 17 carbon dioxide extinguishers (CO2)
- 4 hand pumps
- 45 water fire extinguishers
- 5 dry-powder extinguishers
- 1 fire blanket
- 6 AFDR-system
- 84 emergency light and exit signs 8W
- 1 Inergen Fire eater
- 1 Argonite
- 18 first aid boxes installed in staff kitchens
- 2 AED Heart starters installed at the receptions in KN6 and KN8.