



25 January 2011

**Clarification No 2 for open call for tenders:**

**Framework contract for the provision of security and reception services for the European Environment Agency (EEA)**

**Reference number: EEA/OSE/10/010**

**Question 1:**

Is the service and maintenance of the fire alarm system a part of this tender?

**Answer 1:**

*Yes, the service and maintenance of the fire alarm system is included in this call for tenders.*

**Question 2:**

Is the yearly certification of the fire alarm system (performed today by Dansk Brandteknisk Institut) a part of this tender?

**Answer 2:**

*Yes the yearly certification of the fire alarm system is part of this call for tenders.*

*In Annex 4 of the tender specifications, "Current security installations and equipment at the EEA", the 4<sup>th</sup> paragraph concerning the automatic fire alarm system shall be replaced by the following (modifications are highlighted in blue):*

**Automatic fire alarm system (ABA)**

The ABA includes:

- One central fire alarm unit including power supply and emergency power supply
- One signal transmission device for contact with the Copenhagen fire service
- One signal transmission device for contact with the Dansikring A/S control centre
- 93 alarm sirens
- 149 optical smoke detectors
- 250 ion smoke detectors
- 253 heat detectors
- 53 alarm buttons

*The installations are subject to a yearly inspection carried out by Dansk Brand-og Sikringsteknisk Institut (The Danish Fire Safety Institute).*

*For convenience sake a consolidated version of Annex 4 including the above modifications is available on <http://www.eea.europa.eu/about-us/tenders/eea-ose-10-010-framework>*